



AIRBAG - SCHRANK TYP 90 / 900 AIR NACH DIN EN 14470-1 (TYP 90)

Die Lagerung von Explosivstoffen und Gegenständen mit Explosivstoffen, wie z.B. Airbag- und Gurtstraffereinheiten, ist in unmittelbarer Nähe von Arbeitsplätzen unzulässig. Ausgenommen hiervon ist die Lagerung in speziell dafür geeigneten Lagereinrichtungen.

Zugelassen zur Lagerung von Airbag- und Gurtstraffereinheiten der Klassen PT1 und PT2 der Lagergruppe 1.4

- ◆ Eignungsfeststellung durch BAM Berlin mittels Sprengtest
- ◆ Brandschutz durch Nachweis der Feuerwiderstandsfähigkeit von > 90 Minuten (Typprüfung nach DIN EN 14470-1 - Typ 90)
- ◆ Isolierung nach DIN 4102
- ◆ Außenkorpus RAL 7035 - lichtgrau
- ◆ Türen RAL 1007 - narzissengelb
- ◆ Zwei Flügeltüren über Zylinderschloss abschließbar - verstärktes Schließsystem
- ◆ Bodenabschlussschiene aus Edelstahl - Niro Raute
- ◆ Innenkorpus aus HPL beschichteten Platten in RAL 7035 - lichtgrau
- ◆ Kennzeichnung nach DIN EN 14470-1 / TRGS 510 / ISO 3864 / ASR A1.3

◆ Türfeststellanlage



**SiS Typ 90 / 900 Air,
Artikel-Nr. B80-2879-A**

**Geprüft
durch BAM Berlin**



**SiS Typ 90 / 900 Air,
Artikel-Nr. B80-2879-A**

Innenausstattung:

- ◆ Vier Lagerebenen im Raster von 25 mm höhenverstellbar
- ◆ Erhöhte Korrosionsbeständigkeit durch komplette Verzinkung der Regaleinbauten
- ◆ Komplett elektrostatische Verbindung aller Einbauteile und Inneneinrichtung durch integrierten Erdungsbaum - Erdungsanschluss auf dem Schrankdach

Schrank-Typ	SiS Typ 90 / 900 Air
Außenmaße B x T x H in mm	900 x 900 x 1935
Innenmaße B x T x H in mm	797 x 735 x 1740
Flügeltüren	2
Gewicht in kg	530
Artikel-Nr., Außenkorpus RAL 7035 - lichtgrau,	
Flügeltüren RAL 1007 - narzissengelb	B80-2879-A
Zubehör	Artikel-Nr.
Unterfahrsockel, brandkammergetestet B x T x H in mm = 900 x 900 x 113	B80-2713-A



ERFÜLLT DIE ANFORDERUNGEN DER ZWEITEN VERORDNUNG ZUM SPRENGSTOFFGESETZ § 2, ANHANG NR. 4 BEI DER LAGERUNG VON KLEINEN MENGEN GEMÄSS PRÜFBERICHT BAM BERLIN !



AIRBAG - CABINET TYPE 90 / 900 AIR AS PER DIN EN 14470-1 (TYPE 90)

The storage of explosive substances and devices containing explosive substances, such as airbag and seat belt tensioning units, is not permitted in the direct vicinity of the workplace. An exception is made for storage devices that have been specially designed for this purpose.

Approved for storage of airbags and seat belt tensioning units of class PT1 and PT2 as well as storage group 1.4

- ◆ Whole construction tested and approved by BAM Berlin by explosion test
- ◆ Fire resistance by test certificate of >90 minutes (according to DIN EN 14470-1 - type 90)
- ◆ Insulation according to DIN 4102
- ◆ Outer body made from powder-coated sheet steel in RAL 7035 - light grey
- ◆ Doors in RAL 1007 - daffodil yellow
- ◆ Doors with cylinder lock - special safety lock system
- ◆ Stainless steel base plate - Niro Rhombus
- ◆ Inner body made from HPL-coated sheets RAL 7035 - light grey
- ◆ Markings according to DIN EN 14470-1 / TRGS 510 / ISO 3864 / ASR A1.3
- ◆ **door hold-open device**

storeLAB
by LeCompt



SiS Type 90 / 900 Air,
Article no. B80-2879-A

Approved
by BAM Berlin



SiS Type 90 / 900 Air,
Article no. B80-2879-A

With inner fittings:

- ◆ Four storing levels height-adjustable at intervals of 25 mm
- ◆ Corrosion resistance by galvanized shelf system
- ◆ Complete electrostatic interconnection of all components and inner fittings by built-in grounding cable harness - grounding connection on cabinet roof

Model	SiS Type 90 / 900 Air
External dimensions W x D x H (mm)	900 x 900 x 1935
Internal dimensions W x D x H (mm)	797 x 735 x 1740
Doors	2
Weight (kg)	530
Article no., outer body: RAL 7035 - light grey, doors: RAL 1007 - daffodil yellow	B80-2879-A
Accessories	Article no.
Socle, tested acc. to type 90 cabinets W x D x H (mm) = 900 x 900 x 113	B80-2713-A



Fulfils the requirements of the second directive to the Explosive Substances Law § 2 Annex No. 4 for the storage of small amounts as per Test Report BAM Berlin !